

Official Laboratory Report

Report To: BRIAN W MASTERSON
16350 S D'ARCY ROAD
KINCHELOE MI 49788

Sample ID: LK28980
Work Order: 20802597_03

System Name/Owner:	KINROSS CHARTER TOWNSHIP	WSSN/Pool ID:	3630
Collection Address:	16701 S WATER TOWER DR, KINCHELOE	Source:	TYPE I
Collected By:	GREGORY WRIGHT AND GENE CHAMBE	Site Code:	TP001
Township/Well#/Section:	KINROSS CHARTER TOWNSHIP/WELL #2/	Collector:	Other
County:	Chippewa	Date Collected:	08/17/2022 10:21
Sample Point:	SAMPLE TAP	Date Received:	08/18/2022 11:37
Water System:	Public System Well	Purpose:	Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Per-And Polyfluorinated Alkyl Substances							
11CI-PF3OUdS	Not Detected	ng/L	2	08/19/2022		EPA 537.1	763051-92-9c
9CI-PF3ONS	Not Detected	ng/L	2	08/19/2022		EPA 537.1	756426-58-1d
ADONA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	919005-14-4e
HFPO-DA	Not Detected	ng/L	2	08/19/2022	370	EPA 537.1	13252-13-6b
NEtFOSAA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	2991-50-6
NMeFOSAA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	2355-31-9
PFBS	2	ng/L	2	08/19/2022	420	EPA 537.1	375-73-5
PFDA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	335-76-2
PFDoA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	307-55-1
PFHpA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	375-85-9
PFHxA	Not Detected	ng/L	2	08/19/2022	400000	EPA 537.1	307-24-4
PFHxS	Not Detected	ng/L	2	08/19/2022	51	EPA 537.1	355-46-4
PFNA	Not Detected	ng/L	2	08/19/2022	6	EPA 537.1	375-95-1
PFOA	Not Detected	ng/L	2	08/19/2022	8	EPA 537.1	335-67-1
PFOS	Not Detected	ng/L	2	08/19/2022	16	EPA 537.1	1763-23-1
PFTA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	376-06-7
PFTTrDA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	72629-94-8
PFUnA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	2058-94-8

RL: Reporting Limit

MCL: Maximum Contaminant Level

AL: Action Level

Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)

ng/L: nanograms / Liter (ppt)

MPN: Most Probable Number

CFU: Colony Forming Unit

CAS: Chemical Abstract Service

Laboratory Contact: Marlene Kane

Sample ID: LK28980

Work Order: 20802597_03

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Chippewa County Health Dept.
508 Ashmun, Suite 120
Sault Sainte Marie, MI 49783
906 635-3620

RL: Reporting Limit

MCL: Maximum Contaminant Level

AL: Action Level

Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)

ng/L: nanograms / Liter (ppt)

MPN: Most Probable Number

CFU: Colony Forming Unit

CAS: Chemical Abstract Service

Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: BRIAN W MASTERSON
16350 S D'ARCY ROAD
KINCHELOE MI 49788

Sample ID: LK28978

Work Order: 20802597_01

System Name/Owner:	KINROSS CHARTER TOWNSHIP	WSSN/Pool ID:	3630
Collection Address:	15 GREENWOOD WAY, KINCHELOE	Source:	TYPE I
Collected By:	GREGORY WRIGHT AND GENE CHAMBE	Site Code:	TP007
Township/Well#/Section:	KINROSS CHARTER TOWNSHIP/WELL #7/	Collector:	Other
County:	Chippewa	Date Collected:	08/17/2022 10:45
Sample Point:	SAMPLE TAP	Date Received:	08/18/2022 11:37
Water System:	Public System Well	Purpose:	Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

Per-And Polyfluorinated Alkyl Substances

11CI-PF3OUdS	Not Detected	ng/L	2	08/19/2022		EPA 537.1	763051-92-9c
9CI-PF3ONS	Not Detected	ng/L	2	08/19/2022		EPA 537.1	756426-58-1d
ADONA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	919005-14-4e
HFPO-DA	Not Detected	ng/L	2	08/19/2022	370	EPA 537.1	13252-13-6b
NEtFOSAA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	2991-50-6
NMeFOSAA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	2355-31-9
PFBS	5	ng/L	2	08/19/2022	420	EPA 537.1	375-73-5
PFDA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	335-76-2
PFDoA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	307-55-1
PFHpA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	375-85-9
PFHxA	Not Detected	ng/L	2	08/19/2022	400000	EPA 537.1	307-24-4
PFHxS	Not Detected	ng/L	2	08/19/2022	51	EPA 537.1	355-46-4
PFNA	Not Detected	ng/L	2	08/19/2022	6	EPA 537.1	375-95-1
PFOA	Not Detected	ng/L	2	08/19/2022	8	EPA 537.1	335-67-1
PFOS	Not Detected	ng/L	2	08/19/2022	16	EPA 537.1	1763-23-1
PFTA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	376-06-7
PFTTrDA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	72629-94-8
PFUnA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	2058-94-8

RL: Reporting Limit

MCL: Maximum Contaminant Level

AL: Action Level

Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)

ng/L: nanograms / Liter (ppt)

MPN: Most Probable Number

CFU: Colony Forming Unit

CAS: Chemical Abstract Service

Laboratory Contact: Marlene Kane

Sample ID: LK28978

Work Order: 20802597_01

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Chippewa County Health Dept.
508 Ashmun, Suite 120
Sault Sainte Marie, MI 49783
906 635-3620

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: BRIAN W MASTERSON
16350 S D'ARCY ROAD
KINCHELOE MI 49788

Sample ID: LK28979
Work Order: 20802597_02

System Name/Owner:	KINROSS CHARTER TOWNSHIP	WSSN/Pool ID:	3630
Collection Address:	15846 S COUNTRY CLUB DR, KINCHELOE	Source:	TYPE I
Collected By:	GREGORY WRIGHT AND GENE CHAMBE	Site Code:	TP005
Township/Well#/Section:	KINROSS CHARTER TOWNSHIP/WELL #5/	Collector:	Other
County:	Chippewa	Date Collected:	08/17/2022 10:34
Sample Point:	SAMPLE TAP	Date Received:	08/18/2022 11:37
Water System:	Public System Well	Purpose:	Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

Per-And Polyfluorinated Alkyl Substances

11CI-PF3OUdS	Not Detected	ng/L	2	08/19/2022		EPA 537.1	763051-92-9c
9CI-PF3ONS	Not Detected	ng/L	2	08/19/2022		EPA 537.1	756426-58-1d
ADONA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	919005-14-4e
HFPO-DA	Not Detected	ng/L	2	08/19/2022	370	EPA 537.1	13252-13-6b
NEtFOSAA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	2991-50-6
NMeFOSAA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	2355-31-9
PFBS	Not Detected	ng/L	2	08/19/2022	420	EPA 537.1	375-73-5
PFDA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	335-76-2
PFDaA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	307-55-1
PFHpA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	375-85-9
PFHxA	Not Detected	ng/L	2	08/19/2022	400000	EPA 537.1	307-24-4
PFHxS	3	ng/L	2	08/19/2022	51	EPA 537.1	355-46-4
PFNA	Not Detected	ng/L	2	08/19/2022	6	EPA 537.1	375-95-1
PFOA	Not Detected	ng/L	2	08/19/2022	8	EPA 537.1	335-67-1
PFOS	Not Detected	ng/L	2	08/19/2022	16	EPA 537.1	1763-23-1
PFTA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	376-06-7
PFTTrDA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	72629-94-8
PFUnA	Not Detected	ng/L	2	08/19/2022		EPA 537.1	2058-94-8

RL: Reporting Limit

MCL: Maximum Contaminant Level

AL: Action Level

Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)

ng/L: nanograms / Liter (ppt)

MPN: Most Probable Number

CFU: Colony Forming Unit

CAS: Chemical Abstract Service

Laboratory Contact: Marlene Kane

Sample ID: LK28979

Work Order: 20802597_02

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Chippewa County Health Dept.
508 Ashmun, Suite 120
Sault Sainte Marie, MI 49783
906 635-3620**

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane